Sheet List

		SHEEL LIST
Sheet Count	Sheet Number	Sheet Name
1	LS001	SHEET INDEX, SYMBOLS, ABBREVIATIONS AND NOTES
2	LS002	EQUIPMENT SCHEDULES
3	LS-SAV-021	SAVANNA HABITAT - PROCESS FLOW DIAGRAM
4	LS-FLA-021	FLAMINGO - PROCESS FLOW DIAGRAM
5	LS-GEL-021	GELADA - PROCESS FLOW DIAGRAM
6	LS-ALL-021	ALLIGATOR - PROCESS FLOW DIAGRAM
7	LS101	LSS SITE PLAN
8	LS301	ENLARGED LSS PLAN
9	LS302	ENLARGED LSS PLAN
10	LS303	ENLARGED LSS PLAN
11	LS304	ENLARGED LSS PLAN
12	LS305	ENLARGED LSS PLAN


GENERAL NOTES

 ALL EXPOSED PIPING SHALL BE ADEQUATELY SUPPORTED TO WALLS, CEILINGS AND FLOORS.

ALL PIPE PENETRATIONS AT NEW CONCRETE HYDRAULIC STRUCTURES SHALL HAVE WALL FLANGES; BLOCKOUTS FOR PIPE PENETRATIONS SHALL NOT BE ALLOWED.

CONNECTIONS BETWEEN DISSIMILAR MATERIALS SHALL BE COMPATIBLE IN ALL WAYS

VERIFY SIZE AND LOCATION OF EXISTING OR OTHER DISCIPLINE'S UTILITIES AT ANY PIPE CROSSINGS, OR CONNECTIONS, PRIOR TO CONSTRUCTION.





Sacramento Zoological Soc 3930 W. Land Park Drive Sacramento, CA USA



SH R Studios 250 Madrona Way N.E. Bainbridge Island, WA 1 phone (206) 842-8332



Kimley » Horn









The New Zoo at Elk Grove

SHEET INDEX, SYMBOLS, ABBREVIATIONS AND NOTES

	SHEET SIZE:	ARCH E (36" x 48")
	DATE:	06 October, 2023
	SCALE:	12" = 1'-0"
	CHECKED:	JBF
	SHEET:	

LS001

ı ı: Di

_3001

All reproduction & intellectual property rights reserved © 2023 TJP. Inc.

								P	UMP SCHE	DULE								
DESIGNATION	SERVICE / FUNCTION	QTY	FLOW (GPM)	TDH (FT)	ORIENTATION	DRIVE TYPE	MATERIAI	TYPE	SIZE	MINIMUM			ELECT	TRICAL (MO	TOR)		REMARKS	SPECIFICATION
DESIGNATION	SERVICE / FUNCTION	QIT	PLOW (GPM)	IDH (FI)	ORIENTATION	DRIVE I TPE	MATERIAL	TTPE	SIZE	EFFICIENCY (%)	HP	RPM	VOLTS	PHASE	HERTZ	DRIVE SPEED	KENNAAZ	SPECIFICATION
SAV-PTRN01-001 AND -002	SAVANNA EXHIBIT / TRANSFER PUMP	2	500	35	N/A	N/A	DUCTILE IRON	SUBMERSIBLE			7.5		480	3	60	VFD	XXXX.**/ MINIMILM X* SQLIDS PASSED / PROVIDE CONTROLLER FOR EACH PLIMP INCLUDING SHUT OFF FOR OVER HEATING OR LOW WATER CONDITION AND ALARM FOR SEAL FALILIER. LISTED POWER TO CONTROLLER / PROVIDE 300 SERIES STAINLESS STEEL GUIDE RAIL SYSTEM / PROVIDE CONDUIT AND WIRNS BETWEEN FUR	XXXXXX
FLA-PTRN01-001 AND -002	FLAMINGO EXHIBIT / TRANSFER PUMP	2	400	35	N/A	N/A	DUCTILE IRON	SUBMERSIBLE			7.5		480	3	60	VFD	XXXX.** / MINIMIUM X* SOLIDS PASSED / PROVIDE CONTROLLER FOR EACH PLMP INCLUDING SHUT OFF FOR OVER HEATING OR LIOW WATER CONDITION AND ALAMIR FOR SEAL FALILIRE. LISTED POWER TO CONTROLLER / PROVIDE 300 SERIES STAINLESS STEEL GUIDE RAIL SYSTEM / PROVIDE CONDUIT AND WIRNS BETWEEN FUMP AND CONTROLLER.	XXXXXXX
FLA-PFIL01-001	FLAMINGO EXHIBIT / SAND FILTER PUMP	1	115	60	HORIZONTAL	CLOSE COUPLED	DUCTILE IRON	END SUCTION CENTRIFUGAL			3		480	3	60	VFD	PACO LC OR EQUAL	X00000X
GEL-PTRN01-001 AND -002	GELADA EXHIBIT / TRANSFER PUMP	2	400	35	N/A	N/A	DUCTILE IRON	SUBMERSIBLE			7.5		480	3	60	VFD	XXXX.**/ MINIMILM X* SQLIDS PASSED / PROVIDE CONTROLLER FOR EACH PLIMP INCLUDING SHUT OFF FOR OVER HEATING OR LOW WATER CONDITION AND ALARM FOR SEAL FALILIER, LISTED POWER TO CONTROLLER / PROVIDE 300 SERIES STAINLESS STEEL GUIDE RAIL SYSTEM / PROVIDE CONDUIT AND WIRNS BETWEEN FUMP AND CONTROLLER.	xxxxxx
GEL-PREC01-001	GELADA EXHIBIT / TRANSFER PUMP	1	400	35	N/A	N/A	DUCTILE IRON	SUBMERSIBLE			7.5		480	3	60	VFD	XXXX.**/ MINIMILM X* SQLIDS PASSED / PROVIDE CONTROLLER FOR EACH PLIMP INCLUDING SHUT OF FOR OVER HEATING OR LOW WATER CONDITION AND ALARM FOR SEAL FAILURE IL SUITED POWER FO CONTROLLER / PROVIDE 300 SERIES STAINLESS STEEL GLIDE RAIL SYSTEM / PROVIDE CONDUIT AND WIRMS SETWERN FUMP AND CONTROLLER / PROVIDE CONTROLLER / PROVIDE CONDUIT AND WIRMS SETWERN FUMP AND CONTROLLER / PROVIDE CO	
ALL-PTRN01-001 AND -002	ALLIGATOR EXHIBIT / TRANSFER PUMP	2	300	35	N/A	N/A	DUCTILE IRON	SUBMERSIBLE			5		480	3	60	VFD	XXXX.** / MINIMILM X* SQLIDS PASSED / PROVIDE CONTROLLER FOR EACH PLIMP PACLUTING SHUT OF FOR OVER HEATING OR LOW WATER CONDITION AND ALARM FOR SEAL FAILURE IL SUITED POWER FO CONTROLLER / PROVIDE 300 SERIES STAINLESS STEEL GLIDE RAIL SYSTEM / PROVIDE CONDUIT AND WIRMS SETWERN FUMP AND CONTROLLER / PROVIDE CONTROLLER / PROVIDE CONDUIT AND WIRMS SETWERN FUMP AND CONTROLLER / PROVIDE C	XXXXXXX
ALL-PHEX01-001	ALLIGATOR EXHIBIT / HEATAER PUMP	1	130	35	N/A	N/A	DUCTILE IRON	END SUCTION CENTRIFUGAL			3		480	3	60	VFD	PACO LC OR EQUAL	xxxxxxx

								FILTER SCH	EDULE					
DESIGNATION	SERVICE/FLINCTION	OTY	SIZE	FLOW	ORIENTATION	MEDIA	MATERIAL		ELEC	TRICAL			REMARKS	SPECIFICATION
DESIGNATION	SERVICEFORCTION	QIII	SIZE	(GPM)	ONEWATION	MEDIA	INATERIAL	COMPONENT	HP	VOLTS	PHASE	HERTZ	KEWPOO	SPECIFICATION
								BACKWASH CONTROL MODULE	7.0 AMPS MAX	115-120	1	60	HEX "X2-3" MODEL TANK VERSION BY CM-AQUA TECHNOLOGIES/ WITH FLANGED INLET AND OUTLET	
SAV-FDR001-001 AND -002	SAVANNA EXHIBIT / DRUM FILTER	2		500	HORIZONTAL	MESH DRUM - 30 MICRON HOLE SIZE	316 SS	DRUM MOTOR / VFD	0.75 KW	480	3	60	CONNECTIONS / INCLUDES BACKWASH PUMP WITH MOTOR STARTER, CONTROLS JUNCTION BOX, VFD DRUM MOTOR DRIVE, AND WATER LEVEL SENSOR / LPROVIDE CONDUIT AND WIRING BETWEEN ALL	170028
								RINSE PUMP / MOTOR STARTER	3 KW	480	3	60	COMPONENTS / BACKWASH CONTROLLER IS PRE-WIRED TO ULTRASONIC LEVEL SENSOR WITH 10 FT CABLE	
						MESH DRUM - 30		BACKWASH CONTROL MODULE	7.0 AMPS MAX	115-120	1	60	HEX "X2-2" MODEL TANK VERSION BY CM-AQUA TECHNOLOGIES/ WITH FLANGED INLET AND OUTLET	
FLA-FDR001-001 AND -002	FLAMINGO EXHIBIT / DRUM FILTER	2		400	HORIZONTAL	MICRON HOLE SIZE	316 SS	DRUM MOTOR / VFD	0.75 KW	480	3	60	CONNECTIONS / INCLUDES BACKWASH PUMP WITH MOTOR STARTER, CONTROLS JUNCTION BOX, VFD DRUM MOTOR DRIVE, AND WATER LEVEL SENSOR / LPROVIDE CONDUIT AND WIRING BETWEEN ALL ICOMPONENTS / BACKWASH CONTROLLER IS PRE-WIRED TO ULTRASONIC LEVEL SENSOR WITH 10 FT CABLE	170028
								RINSE PUMP / MOTOR STARTER	3 KW	480	3	60	COMPONENTS / BACKWASH CONTROLLER IS PRE-WIRED TO ULTRASONIC LEVEL SENSOR WITH 10 FT CABLE	
FLA-FSV042-001	FLAMINGO EXHIBIT / SAND FILTER	1	42" DIA	115	VERTICAL	SAND	FRP	N/A	N/A	N/A	N/A	N/A	60" SIDEWALL	170024 & 170062
						MESH DRUM - 30		BACKWASH CONTROL MODULE	7.0 AMPS MAX	115-120	1	60	HEX "X2-2" MODEL TANK VERSION BY CM-AQUA TECHNOLOGIES/ WITH FLANGED INLET AND OUTLET	
GEL-FDR001-001 AND -002	GELADA EXHIBIT / DRUM FILTER	2		400	HORIZONTAL	MICRON HOLE SIZE	316 SS	DRUM MOTOR / VFD	0.75 KW	480	3	60	CONNECTIONS / INCLUDES BACKWASH PUMP WITH MOTOR STARTER, CONTROLS JUNCTION BOX, VFD DRUM MOTOR DRIVE, AND WATER LEVEL SENSOR / LPROVIDE CONDUIT AND WIRING BETWEEN ALL	170028
								RINSE PUMP / MOTOR STARTER	3 KW	480	3	60	COMPONENTS / BACKWASH CONTROLLER IS PRE-WIRED TO ULTRASONIC LEVEL SENSOR WITH 10 FT CABLE	
								BACKWASH CONTROL MODULE	7.0 AMPS MAX	115-120	1	60	HEX "X2-4" MODEL TANK VERSION BY CM-AQUA TECHNOLOGIES/ WITH FLANGED INLET AND OUTLET	
ALL-FDR001-001	ALLIGATOR EXHIBIT / DRUM FILTER	1		600	HORIZONTAL	MESH DRUM - 30 MICRON HOLE SIZE	316 SS	DRUM MOTOR / VFD	0.75 KW	480	3	60	CONNECTIONS / INCLUDES BACKWASH PUMP WITH MOTOR STARTER, CONTROLS JUNCTION BOX, VFD DRUM MOTOR DRIVE, AND WATER LEVEL SENSOR / UPROVIDE CONDUIT AND WING BETWEEN ALL COMPONENTS / BACKWASH CONTROLIER IS PRE-WIRED TO LITERSONIC LEVEL SENSOR WITH 10 FT CABLE.	170028
								RINSE PUMP / MOTOR STARTER	3 KW	480	3	60	COMPONENTS / BACKWASH CONTROLLER IS PRE-WIRED TO ULTRASONIC LEVEL SENSOR WITH 10 FT CABLE	

					02	ZONE S	CHEDU	LE		
DESIGNATION	SERVICE / FUNCTION	QTY	CAPACITY	EL	ECTRICAL			EMERGENCY	RE-MARK'S	SPECIFICATION
DESIGNATION	SERVICE/ FONCTION	QII.	CAPACITI	POWER	VOLTS	PHASE	HERTZ	POWER	NEWWYNG	SPECIFICATION
FLA-OZES01-001	FLAMINGO EXHIBIT / OZONE EQUIPMENT SKID	1	40 G/HR (TWO 20 G/HR UNITS)	30 A	120	1	60	YES	COMPLETE GZONE GENERATION PACKAGE ON SIGD INCLUDING AIR PREP EQUIPMENT AND BACKFLOW PREVENTION J EQUIPMENT MANUFACTUREST TO SPRIPLY SINGLE ELECTRICAL CONNECTION J REFER TO DRAWINGS AND SPECIFICATIONS FOR ALL EQUIPMENT INCLUDED ON SIGD INCLUDE ONE AMBIENT GZONE MONITOR (PEN-DZAMO1-00)/ PROVIDE CONDUIT AND WIRING BETWEEN COMPONENTS PER MANUFACTUREST RECOMMENDATIONS AND LISS DRAWINGS.	170720
FLA-OZOD01-001	FLAMINGO EXHIBIT / OFFGAS DESTRUCT	1	2 SCFM	1 A	120	1	60	YES	PRESSURE TYPE / PROVIDE WITH DEMISTER AND WATER TRAP ASSEMBLY / LSS CONTRACTOR TO PROVIDE CONDUIT AND LOW VOLTAGE WIRING BETWEEN OFFGAS DESTRUCT AND INTERFACE CONTROL PANEL ON OZONE SKID	170720
FLA-OZOD02-001	FLAMINGO EXHIBIT / OFFGAS DESTRUCT	1	100 SCFM	7 A	480	3	60	YES	BLOWER TYPE / LSS CONTRACTOR TO PROVIDE CONDUIT AND LOW VOLTAGE WIRING BETWEEN OFFGAS DESTRUCT AND INTERFACE CONTROL PANEL ON OZONE SKID	170720
FLA-OZCV01-001	FLAMINGO EXHIBIT / CONTACT VESSEL	1	345 GAL (42" DIA. X 95" TALL)	N/A	N/A	N/A	N/A	N/A	PENTAIR STRUCTURAL "COMPOSITE" PROVIDED WITH INTERNAL DIFFUSER SUPPLIED BY OZONE SUPPLIER	170720
FLA-OZJB01-001	FLAMINGO EXHIBIT / OZONE GAS PIPING JUNCTION BOX	1	10 SCFM	5 A	120	1	60	YES	UFC COMPLIANT OZONE GAS DELIVERY JUNCTION BOX / INTEGRAL AMBIENT MONITOR FOR LEAK DETECTION AND BLOWER TO VENT CONTAINMENT PIPING INTO OZONE ROOM / PROVIDE CONDUIT AND WIRING PER MANUFACTURER'S RECOMMENDATIONS	170720
FLA-OZWA01-001 AND 002	FLAMINGO EXHIBIT / WARNING ALARM	2	N/A	N/A	N/A	N/A	N/A	N/A	POWER SUPPLIED BY OZONE GENERATOR PANEL / LSS CONTRACTOR TO PROVIDE CONDUIT AND LOW VOLTAGE WIRING BETWEEN WARNING ALARM AND INTERFACE CONTROL PANEL ON OZONE SKID	170720
FLA-OZAM01-002	FLAMINGO EXHIBIT / AMBIENT OZONE MONITOR	1	N/A	N/A	N/A	N/A	N/A	N/A	LOCATED NEAR POINT OF INJECTION / POWER SUPPLIED BY OZONE GENERATOR PANEL / LSS CONTRACTOR TO PROVIDE CONDUIT AND LOW VOLTAGE WIRING BETWEEN AMBIENT ALARM AND INTERFACE CONTROL PANEL ON OZONE SKID	170720

						SCREEN S	CHEDU	LE				
DESIGNATION	SERVICE/FUNCTION	QTY	SIZE	FLOW (GPM)	MEDIA	MATERIAL	EL	ECTRICAL R	EQUIREMEN	TS	REMARKS	SPECIFICATION
DEGICIETION	SERVICE GROTION	Q	OLL	12011 (Gr III)	made:	MATERIAL .	HP	VOLTS	PHASE	HERTZ	I SLITTE GOD	Or Edit Identificity
SAV-SST001-001	SAVANNA EXHIBIT / STATIC SCREEN	1	120" WIDE	1000	WEDGE WIRE SCREEN - OPENING SIZE .1"	316 SS	N/A	N/A	N/A	N/A	PARKSON "HS 120"	170029
FLA-SST001-001	FLAMINGO EXHIBIT / STATIC SCREEN	1	120" WIDE	800	WEDGE WIRE SCREEN - OPENING SIZE .1"	316 SS	N/A	N/A	N/A	N/A	PARKSON "HS 120"	170029
GEL-SST001-001	GELADA EXHIBIT / STATIC SCREEN	1	120" WIDE	800	WEDGE WIRE SCREEN - OPENING SIZE .1"	316 SS	N/A	N/A	N/A	N/A	PARKSON "HS 120"	170029

					U.V.	STERIL	IZER S	CHEDU	LE	
DESIGNATION	SERVICE / FLINCTION	OTY	DESIGN FLOW	MINIMUM CAPACITY		ELECT	RICAL		REMARKS	SPECIFICATIONS
DESIGNATION	SERVICE / FUNCTION	QIT	(GPM)	(mJ/cm2)	POWER (AMPS)	VOLTS	PHASE	HERTZ	REMARKS	SPECIFICATIONS
SAV-UVS001-001	SAVANNA EXHIBIT / ULTRAVIOLET STERILIZER	1	1000	30	18	120	1	60	RG*ALHEDITE / RROUNDE WITH IT FLANCED CONNECTION AND STANDARD HIS CONTROLLER / ELECTRICAL CONTROLLOR TO PROVIDE POWER TO CONTROLLER BOX LESS CONTRACTOR TO INSTALL MANUFACTURER PROVIDED CALLES BETWEEN THE UV AND CONTROLLER	170770
FLA-UVS001-001	FLAMINGO EXHIBIT / ULTRAVIOLET STERILIZER	1	800	30	15	120	1	60	RK2 "ALHESDS" / PROVIDE WITH S" FLANGED CONNECTION AND STANDARD HM CONTROLLER / ELECTRICAL CONTRACTOR TO PROVIDE POWER TO CONTROLLER BDV. I. SS CONTRACTOR TO INSTALL MANUFACTURER PROVIDED CARLES SERVICES IN THE U. AND CONTROLLER CONTROLLER.	170770
GEL-UVS001-001	GELADA EXHIBIT / ULTRAVIOLET STERILIZER	1	800	30	15	120	1	60	RK2 "ALHRSDS" / PROVIDE WITH IS" FLANGED CONNECTION AND STANDARD HIM CONTROLLER / ELECTRICAL CONTRACTOR TO PROVIDE POWER TO CONTROLLER BOX / LSS CONTRACTOR TO INSTALL MANUFACTURER PROVIDED CARLES SERVICES IN THE UNIT CONT	170770
FLA-UVS001-001	ALLIGATOR EXHIBIT / ULTRAVIOLET STERILIZER	1	600	30	12	120	1	60	PIC "ALHESIS" / PROVICE WITH F FLANGED CONSECTION NOS STANDARD HAS CONTROLLER. ELECTROCAL CONTRACTOR TO PROVICE POWER FOR CONTROLLER DOX LSS CONTRACTOR TO INSTALL MANUFACTURER PROVIDED CABLES BETWEEN THE UV AND CONTROLLER.	170770

			1	HEATEF	SCHE	DULE				
DESIGNATION	SERVICE / FUNCTION	QTY	CAPACITY (kW)	FLOW		ELECT	TRICAL		REMARKS	SPECIFICATION
DEGGIVENOR	GENOL/TONON	4	Gra Horri (KIII)	(GPM)	POWER	VOLTS	PHASE	HERTZ	TALIFF AND	Ci Loii iorrioir
ALL-HTR001-001	ALLIGATOR EXHIBIT / HEATER	1	60	130	87 AMPS	480	3	60	TITAN OPTIMA / INTEGRAL TEMPERATURE CONTROLLER	XXXXXXX





SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn









The New Zoo at Elk Gro

EQUIPMENT SCHEDULES


	SHEET SIZE:	ARCH E (36" x 48")
	DATE:	06 October, 2023
	SCALE:	12" = 1'-0"
	CHECKED:	JBF
	SHEET:	

LS002

Schematic Plans

PROJECT OF SHI STLICKS, NC. USE OR REPRODUCTION PRO-MISTID WITHOUT FROM WRITTIN NUMBERGY, AL. RIGHTS RESERVED.

All reproduction & intellectual property rights reserved © 2023 TJP, Inc.







SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn









The New Zoo at Elk Grove

LSS SITE PLAN

SHEET SIZE:	ARCH E (36" x 48")
DATE:	06 October, 2023
SCALE:	1/64" = 1'-0"
CHECKED:	JBF

LS101







SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn








The New Zoo at Elk Grove

ENLARGED LSS PLAN

SHEET SIZE:	ARCH E (36" x 48")
DATE:	06 October, 2023
SCALE:	1/8" = 1'-0"
CHECKED:	JBF

LS301







SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn







The New Zoo at Elk Grove

ENLARGED LSS PLAN

SHEET SIZE:	ARCH E (36" x 48")
DATE:	06 October, 2023
SCALE:	As indicated
CHECKED:	JBF
SHEET:	

LS302







SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn










ENLARGED LSS PLAN

SHEET SIZE:	ARCH E (36" x 48")
DATE:	06 October, 2023
SCALE:	1/8" = 1'-0"
CHECKED:	JBF
SHEET:	

LS303








SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn










The New Zoo at Elk Grove

ENLARGED LSS PLAN

SHEET SIZE:	ARCH E (36" x 48")
DATE:	06 October, 2023
SCALE:	1/8" = 1'-0"
CHECKED:	JBF

LS304







SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn








The New Zoo at Elk Grove

ENLARGED LSS PLAN

	SHEET SIZE:	ARCH E (36" x 48")
	DATE:	06 October, 2023
	SCALE:	1/8" = 1'-0"
	CHECKED:	JBF
	SHEET:	

LS305








SHR Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn







The New Zoo at Elk Grove


ALLIGATOR - PROCESS FLOW DIAGRAM

SHEET SIZE:	ARCH E (36" x 48")
DATE:	06 October, 2023
SCALE:	
CHECKED:	JBF
SHEET:	

LS-ALL-021

Schematic Plans

ALLIGATOR - PROCESS FLOW DIAGRAM







SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com

NOLL & TAM ARCHITECTS

Kimley»Horn








The New Zoo at Elk Grove

FLAMINGO - PROCESS FLOW DIAGRAM

	SHEET SIZE:	ARCH E (36" x 48")
	DATE:	06 October, 2023
	SCALE:	
	CHECKED:	JBF
	SHEET:	

LS-FLA-021







SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn










The New Zoo at Elk Grove

GELADA - PROCESS FLOW DIAGRAM

	SHEET SIZE:	ARCH E (36" x 48")
	DATE:	06 October, 2023
	SCALE:	
	CHECKED:	JBF
	SHEET:	

LS-GEL-021







SH R Studios 250 Madrona Way N.E. #220 Bainbridge Island, WA 98110 phone (206) 842-8332 shrstudios.com



Kimley»Horn









The New Zoo at Elk Grove

SAVANNA HABITAT -PROCESS FLOW DIAGRAM

LS-SAV-021