



NOTE:

1. ALL WIRE SHALL BE TAPED AND BUNDLED EVERY TEN FEET AND SHALL BE INSTALLED AS PER LOCAL CODE.
2. SHUT-OFF VALVES 3" AND SMALLER SHALL BE SCH. 80 BALL VALVES. VALVES LARGER THAN 3" SHALL BE BRASS GATE VALVES.
3. ALL VALVE BOXES AND LIDS WITHIN THE SIDEWALK SHALL BE OF TRAFFIC RATED QUALITY.

DATE: 01/18/2007	NOT TO SCALE
REVISION	APPROVED
BY	DATE

CITY OF ELK GROVE - PUBLIC WORKS

REMOTE CONTROL VALVE

APPROVED BY:

CITY ENGINEER

DRAWING NUMBER



L-3